



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 12/29/09

Code 50.11.1.5.1-09

#### INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title R703.7.4.2 Air space		Page 369
Proponent Lynn Madden	Title	
Address 9805 Chapel Road Centerville, IN 47330		Phone 765-623-1640
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input checked="" type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Delete the text of Section R703.7.4.2 and substitute to read as follows: The masonry veneer shall be separated from the sheathing by an air space of not less than <math>\frac{3}{4}</math> inch (19 mm) but not more than 4 <math>\frac{1}{2}</math> inches (114 mm). The weather-resistant sheathing paper as required by Section R703.2 is not required over water-repellant sheathing materials installed according to manufacturer's instructions. Mortar is permitted to encroach into the air space or make incidental contact with the sheathing or the sheathing paper or equivalent.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal brings forward an amendment from the 2005 Indiana Residential Code.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		